



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Dharinda, P.O.:- Tamluk, Purba Medinipur, Pin:- 721636

Memo No.:FSR/0125186231400308

Date : 16-10-2025

From :
Divisional Fire Officer
Purba Medinipur Division,
West Bengal Fire & Emergency Services

To :
BHAVANS NETAJI SUBHASH CHANDRA BOSE VIDYANIKETAN
VILL. - AZAD HIND NAGAR, P.O. - HALDIA TOWNSHIP, P.S. - HALDIA, DIST. - PURBA MEDINIPUR, PIN -
721607(W.B.)

Sub : Fire Safety Certificate in respect of an existing G+II Storied School Building under Group Educational in the name & style of BHAVANS NETAJI SUBHAS CHANDRA BOSE VIDYANIKETAN at Premises no.- Mouza- Biswanath Duttarchak, Plot No.- 67P, 68P, 69P, 71P, 202P, 204P, 206P, 207P, 208P, 209P, 210P, 211P, 212P, 215P, JL No.- 194, Khatian No.- 216, 217P, 220P, 221P, 222P, 223P, 224P, 383P, PO- Pitambarchak, PS- Haldia, District- Purba Medinipur- 721455.

This is in reference to your AIN 211892506300008309 dated 22-Sep-2025 regarding Fire Safety Certificate in respect of an existing G+II Storied School Building under Group Educational in the name & style of BHAVANS NETAJI SUBHAS CHANDRA BOSE VIDYANIKETAN at Premises no.- Mouza- Biswanath Duttarchak, Plot No.- 67P, 68P, 69P, 71P, 202P, 204P, 206P, 207P, 208P, 209P, 210P, 211P, 212P, 215P, JL No.- 194, Khatian No.- 216, 217P, 220P, 221P, 222P, 223P, 224P, 383P, PO- Pitambarchak, PS- Haldia, District- Purba Medinipur- 721455.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of buildings shall be made with low flame spread material confirming to



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300008309

the I.S. Specification.

3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
4. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. A Fire control room including a closed circuit TV system shall have to be maintained which observe all the floors of the building.
6. The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Buildings.
7. The employees and security staff shall be conversant with installed fire fighting equipment's of the buildings and to operate in the event of fire and testing.
8. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
9. A trained Fireman shall be maintained round the clock for fire safety of the building.
10. First Aid fire fighting system shall be provided as per I.S. specifications.
11. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Buildings to keep them in perfectly good working condition at all the times.
12. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Electrical Ducts shall have to be sealed vertically and horizontally in proper manner immediately.
14. Periodical flashing of water in the Hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
15. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
16. The Fire Safety Certificate is valid for three years and has to be renewed every three years from the date of issue of this letter.

This certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Valid Upto : 14-Oct-2028

Memo No.:FSR/0125186231400308



Signature valid

Digitally Signed.
Name: SHUBRANGSHU MAZUMDER
Date: 16-Oct-2025 16:54:05
Reason: D-Sign
Location: E-Dist 20

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300008309